



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

DAY	...	Authority	Phos	Other	Y/N
1					
2					
3	7.40		1.00	16	Y
4					
5					
6	7.41		1.00	16	Y
7					
8					
9					
10	7.42		1.00	16	Y
11					
12					
13	7.38		1.00	16	Y
14					
15					
16					
17	7.40		1.00	16	Y
18					
19					
20	7.40		1.00	16	Y
21					
22					
23					
24	7.41		1.00	16	Y
25					
26					
27	7.40		1.00	16	Y
28					

<<Have Minimums been met for this day?

ENTRY POINT

9	1	7	1	7
---	---	---	---	---

PWS: 41

System Name: Diamond Hill RV

Entry Point EP-A

Sample Period Feb-26

Number of excursions* during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursion are cumulative)

For OHA Use Only

Minimum Water Quality Parameters as set by

ph	7	
Alk		Alkalinity
PO4	1	Orthophosphate
Other		

Print Name: Secret Spencer

Signature:

Date: 3/2/2026

Send to DWP within 10 days after end of sampling period

DWP.DMCE@odhsoha.oregon.gov