

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	6.6				
6					
7					
8					
9					
10					
11	8.5				
12					
13					
14					
15					
16					
17					
18	8.5				
19					
20					
21					
22					
23					
24					
25					
26					
27					
28	8.5				
29					
30					
31	8.5				

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91805

System Name: ELMIRA HIGH/ELEMENTARY

Entry Point: WELL

Sample Period: JAN 2022  
Month/Year

Number of excursions\* during this month: 1  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: ?  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2

Alk   (Alkalinity)

PO4   (Orthophosphate)

Other   ( )

Print Name: JEFF THIESSEN

Signature: *[Signature]*

Date: 2-8-22

Send to DWP within 10 days after end of sampling period

(N = Excursion) Total N's