

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12	7.6				Y
13					
14					
15					
16					
17					
18					
19					
20	7.6				Y
21					
22					
23					
24					
25					
26					
27	7.7				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: ELMIRA HIGH/KLEM.

Entry Point: WELL

Sample Period: SEPT 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: JEFF THIESSEN

Signature: [Signature]

Date: 10-4-2022

Send to DWP within 10 days after end of sampling period

(N = N = Excursion) Total N's