

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.9				N
6					
7					
8					
9					
10					
11					
12	7.9				N
13					
14					
15					
16					
17					
18					
19	7.7				N
20					
21					
22					
23					
24					
25					
26	8.0				N
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Entry Point: Elmira High Pump

Sample Period: Dec. 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Daniel Pruteman
Signature: Dad A A
Date: 1/11/2023

Send to DWP within 10 days after end of sampling period

(N = Excursion) Total N's 0