

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.7				Y
7					
8					
9					
10					
11					
12					
13	7.7				Y
14					
15					
16					
17					
18					
19					
20	7.6				Y
21					
22					
23					
24					
25					
26					
27	7.8				Y
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91805

System Name: Elmira High / Elementary

Entry Point: Pump house

Sample Period: March 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity):

PO4 (Orthophosphate)

Other ()

Print Name: Daniel Puterman

Signature: *Daniel Puterman*

Date: 4.3.23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0