



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.8				Y
4					
5					
6					
7					
8					
9					
10	7.8				Y
11					
12					
13					
14					
15					
16					
17	7.7				Y
18					
19					
20					
21					
22					
23					
24	7.8				Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 91805

System Name: Elmira High / Elementary

Entry Point: Pump House

Sample Period: April 2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH: 7.2

Alk: (Alkalinity)

PO4: (Orthophosphate)

Other: ()

Print Name: Daniel Prytoman

Signature: *Daniel Prytoman*

Date: 4/24/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0