

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.6				Y
6					
7					
8					
9					
10					
11					
12	8.1				Y
13					
14					
15					
16					
17					
18					
19	8.0				Y
20					
21					
22					
23					
24					
25					
26	7.9				Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91805

System Name: Elmira High / Elementary

Entry Point: Pump House

Sample Period: Jun 2023  
Month/Year

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months:       
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

Print Name: Daniel Putzman

Signature: *Daniel Putzman*

Date: 7/3/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0