

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.6				Y
5					
6					
7					
8					
9					
10					
11	8.1				Y
12					
13					
14					
15					
16					
17					
18	8.2				Y
19					
20					
21					
22					
23					
24					
25	8.0				Y
26					
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

9	1	8	0	5
---	---	---	---	---

System Name: Elmira High / Elementary

Entry Point: Pump House

Sample Period: June 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

— For OHA use only —

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Daniel Pruteman

Signature: Daniel Pruteman

Date: 7.3.25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0