

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	8.3				Y
3					
4					
5					
6					
7					
8					
9	7.6				Y
10					
11					
12					
13					
14					
15					
16	7.8				Y
17					
18					
19					
20					
21					
22					
23	7.5				Y
24					
25					
26					
27					
28					
29					
30					
31	7.7				Y
(No = N = Excursion) Total N's					2

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Entry Point: Pump House

Sample Period: July 2025
Month/Year

Number of excursions* during this month: 2
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

--For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk _____ (Alkalinity)
PO4 _____ (Orthophosphate)
Other _____ (_____)

Print Name: Daniel Pritzman

Signature: [Signature]

Date: 8.4.25

Send to DWP within 10 days after end of
sampling period