

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.6			Y	
4					
5					
6					
7					
8					
9					
10	7.6			Y	
11					
12					
13					
14					
15					
16					
17	7.4			Y	
18					
19					
20					
21					
22					
23	7.6			Y	
24					
25					
26					
27					
28					
29					
30					
31	7.6			Y	

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Entry Point: Pump House

Sample Period: December 2025

Month/Year

Number of excursions* during this month: 6

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 6

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

—For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Daniel Putman

Signature: D. Putman

Date: 1-5-26

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 6

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>