Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.9				Y
5					
6					
7					
8					
9					
10					
11	7.7				Y
12					
13					
14					
15					
16					
17					
18	7.83	New Tester			Y
19					
20					
21					
22					
23					
24					
25	7.87				Y
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Entry Point: Pump House

Sample Period: March 2026
Month/Year

Number of excursions* during this month: Ø
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:___
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		*(Alkalinity)*
PO4		*(Orthophosphate)*
Other		(_____)

Print Name: Daniel Pruteman
Signature: [signature]
Date: 4.2.26

Send to DWP within 10 days after end of sampling period