

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	other	Y/N
10/4	Kitchen Sink	6.7				N
10/11	Kitchen Sink	6.4				N
10/18	Kitchen Sink	6.2				N
10/25	Kitchen Sink	6.7				N

<Has sample met the minimums? **DISTRIBUTION**

PWS ID: 41 91805
 System Name: ELMIRA HS / ELMIRA Elem.
 Sample Period: Oct. 2021
Month/Year
 Sample Frequency: Weekly
 Distribution Samples required: 4

Number of excursions during this Sample Period = 4

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Michelle Marshall
 Signature: [Signature]
 Date: 11/9/21

(N = No = Excursion) Total N's 4

Send to Drinking Water Program within 10 days after end of sampling period:
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>