

Lead & Copper Rule Corrosion Control

DAY	ID#	Sample Location	pH	Alk	PO4	other	Y/N
	7		7.7				Y
	14		7.6				Y
	21		6.8				Y
	28		6.8				Y

<Has sample met the minimums? **DISTRIBUTION** -ECS

PWS ID: 41 9 1 8 1 [Icon]

System Name: Elmira High School/E-ECS

Sample Period: 11 / 2022
Month/Year

Sample Frequency: _____

Distribution Samples required: _____

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Daniel Pruteman

Signature: [Signature]

Date: 11/28/2022

(N = No = Excursion) Total N's 0