

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1						
2*		8.0				Y
3						
4						
5						
6						
7						
8						
9						
10						
11						
12		7.8				Y
13						
14						
15						
16		7.9				Y
17						
18						
19						
20						
21						
22						
23		7.8				Y
24						
25						
26						
27						
28						
29						
30		7.5				Y
31						
(N = No = Excursion) Total N's						0

<Has sample met the minimums?

**DISTRIBUTION**

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Sample Period: Oct 2023  
Month/Year

Sample Frequency: Weekly

Distribution Samples required: \_\_\_\_\_

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

— For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<span style="border: 1px solid black; padding: 2px;">7.2</span>	
Alk	<span style="border: 1px solid black; padding: 2px;"></span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;"></span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;"></span>	(_____)

Print Name: Daniel Pruteman

Signature: [Signature]

Date: 11.1.23