

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1		7.6				Y
2						
3						
4						
5						
6						
7						
8		7.6				Y
9						
10						
11						
12						
13						
14						
15		7.5				Y
16						
17						
18						
19						
20						
21						
22		7.6				Y
23						
24						
25						
26						
27						
28						
29		7.4				Y
30						
31						

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Sample Period: April 2024
Month/Year

Sample Frequency: Weekly

Distribution Samples required: _____

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

—For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Daniel Prutzman

Signature: 

Date: 5.3.24

(N = No = Excursion)

Total N's

0