

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1						
2						
3						
4						
5						
6		7.7				Y
7						
8						
9						
10						
11						
12						
13		7.5				Y
14						
15						
16						
17						
18						
19						
20		7.7				Y
21						
22						
23						
24						
25						
26						
27						
28		7.7				Y
29						
30						
31						

<Has sample met the minimums?

**DISTRIBUTION**

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Sample Period: May 2024  
Month/Year

Sample Frequency: Weekly

Distribution Samples required: \_\_\_\_\_

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

--- For OHA use only ---

**Minimum Water Quality Parameters as set by**

pH 7.2  
 Alk  (Alkalinity)  
 PO4  (Orthophosphate)  
 Other  (\_\_\_\_\_)

Print Name: Daniel Pusterman

Signature: *Dan Pusterman*

Date: 6/3/24

(N = No = Excursion) Total N's 0