

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1		7.9				Y
2						
3						
4						
5						
6						
7						
8						
9						
10						
11		7.9				Y
12						
13						
14						
15						
16						
17						
18						
19		8.0				Y
20						
21						
22		8.1				Y
23						
24						
25						
26						
27						
28						
29		8.0				Y
30						
31						
(N = No = Excursion)						<b>Total N's</b> <u>0</u>

<Has sample met the minimums?

**DISTRIBUTION**

PWS ID: 41 9 1 8 0 5

System Name: Elmira High / Elementary

Sample Period: July 2024  
Month/Year

Sample Frequency: Weekly

Distribution Samples required: \_\_\_\_\_

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

— For OHA use only —

**Minimum Water Quality Parameters as set by**

pH 7.2  
 Alk  (Alkalinity)  
 PO4  (Orthophosphate)  
 Other ( )

Print Name: Daniel Pustan

Signature: [Signature]

Date: 8-5-24