

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1						
2						
3						
4		7.8				Y
5						
6						
7						
8						
9						
10						
11		7.7				Y
12						
13						
14						
15						
16						
17						
18		7.81		New Tester		Y
19						
20						
21						
22						
23						
24						
25		7.87				Y
26						
27						
28						
29						
30						
31						
(N = No = Excursion) Total N's						0

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41

System Name: Elmira High / Elementary

Sample Period: March 2024
Month/Year

Sample Frequency: Weekly

Distribution Samples required: 0

Number of excursions during this Sample Period = _____

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

— For OHA use only —

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Daniel Prutman

Signature: [Signature]

Date: 4.2.24