



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.94				
3					
4					
5	7.92				
6					
7					
8	7.88				
9					
10					
11					
12	7.84				
13					
14	7.87				
15					
16	7.83				
17					
18					
19	7.81				
20					
21					
22					
23	7.83				
24					
25					
26					
27	7.8				
28					
29	7.82				
30					
31					

<<Have minimums been met for this day?

County: Lane      Agency: LANE COUNTY

## ENTRY POINT

### EP-A

### PWS ID 4191810

### FERN RIDGE MIDDLE SCHOOL

Sample period: APRIL 2021  
Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.8

**Print Name:** JEFF THIESSEN

**Signature:** [Signature]

**Date Phone#:** 591-935-2253

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0