

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	8.5				Y
5					
6					
7					
8					
9					
10					
11	8.5				Y
12					
13					
14					
15					
16					
17					
18	8.5				Y
19					
20					
21					
22					
23					
24					
25	8.5				Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91810

System Name: FEEN RIDGE MIDDLE SCHOOL

Entry Point: Well

Sample Period: OCT 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH: 7.8

Alk: (Alkalinity)

PO4: (Orthophosphate)

Other: ()

Print Name: J. JESSEN

Signature: [Signature]

Date: 10-31-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

mm
11/10