

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	8.5				Y
5					
6					
7					
8					
9					
10					
11	8.5				Y
12					
13					
14					
15					
16					
17					
18					
19	8.5				Y
20					
21					
22					
23					
24					
25	8.5				Y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: FERN RIDGE MIDDLE SCHOOL

Entry Point: WELL

Sample Period: APRIL 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: JEFF THIESSEN

Signature: [Signature]

Date: 5-10-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's