



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	8.2				Y
6					
7					
8					
9					
10					
11					
12	8.5				Y
13					
14					
15					
16					
17					
18					
19	8.4				Y
20					
21					
22					
23					
24					
25					
26	8.4				Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 91810

System Name: Fern Ridge Middle School

Entry Point: Pump House

Sample Period: June 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.8

Alk   (Alkalinity)

PO4   (Orthophosphate)

Other   ( )

Print Name: Daniel Pruteman

Signature: *Daniel Pruteman*

Date: 7/3/23

Send to DWP within 10 days after end of sampling period

(N = Excursion) Total N's 2