

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----------------------|-----|------|-------|-----|
| 1 | | | | | |
| 2 | 8.2 | | | | Y |
| 3 | | | | | |
| 4 | | | | | |
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | 8.1 | | | | Y |
| 9 | | | | | |
| 10 | | | | | |
| 11 | | | | | |
| 12 | | | | | |
| 13 | | | | | |
| 14 | | | | | |
| 15 | NO School / Ice Storm | | | | |
| 16 | | | | | |
| 17 | | | | | |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | | | | | |
| 22 | | | | | |
| 23 | 8.5 | | | | Y |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | 8.1 | | | | Y |
| 30 | | | | | |
| 31 | | | | | |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 9 | 1 | 8 | 1 | 0 |
|---|---|---|---|---|

System Name: Fern Ridge Middle School

Entry Point: Pump House

Sample Period: January 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

— For OHA use only —

Minimum Water Quality Parameters as set by

| | | |
|-------|-----|------------------|
| pH | 7.8 | |
| Alk | | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Other | | (_____) |

Print Name: Daniel Pruteman
 Signature: [Signature]
 Date: 1/30/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0