

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.9				Y
3					
4					
5					
6					
7					
8					
9	7.9				Y
10					
11					
12					
13					
14					
15					
16	8.0				Y
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30	8.0				Y
31					
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

9	1	8	1	0
---	---	---	---	---

System Name: Fern Ridge Middle School

Entry Point: Pump House

Sample Period: December 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

7.8
-----

  
 Alk 

--

 (Alkalinity)  
 PO4 

--

 (Orthophosphate)  
 Other 

--

 (\_\_\_\_\_)

Print Name: Dan Puterman

Signature: [Signature]

Date: 1.6.25

Send to DWP within 10 days after end of sampling period