

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.2				Y
2					
3					
4					
5					
6					
7					
8	8.2				Y
9					
10					
11					
12					
13					
14					
15	8.2				Y
16					
17					
18					
19					
20					
21					
22	8.3				Y
23					
24					
25					
26					
27					
28					
29	8.2				Y
30					
31					

(No = N = Excursion) **Total N's** 8

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41 

9	1	8	1	0
---	---	---	---	---

System Name: Fern Ridge Middle School

Entry Point: Pump House

Sample Period: October 2025

Month/Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was  
less than the minimum required)

**Total excursions during the previous 5 months:** \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

— For OHA use only —

**Minimum Water Quality  
Parameters as set by**

pH	<u>7.8</u>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Daniel Prutman

Signature: D. Prutman

Date: 10/14/25

Send to DWP within 10 days after end of  
sampling period