

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	Sample Location	pH	Alk	PO4	Other	Y/N	
1							
2							
3							
4							
5		8.1				Y	
6							
7							
8							
9							
10							
11							
12		7.9				Y	
13							
14							
15							
16							
17							
18							
19							
20							
21							
22		8.3				Y	
23							
24							
25							
26							
27							
28		8.4				Y	
29							
30							
31							
(N = No = Excursion)						Total N's	0

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 9 1 8 1 0

System Name: Fern Ridge Middle

Sample Period: August 2024
Month/Year

Sample Frequency: Weekly

Distribution Samples required: _____

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

— For OHA use only —

Minimum Water Quality Parameters as set by

pH 7.8
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other (_____)

Print Name: Daniel Prutzman

Signature: [Signature]

Date: 9.6.24