

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1						
2						
3						
4						
5						
6						
7		8.0				Y
8						
9						
10						
11						
12						
13						
14		8.1				Y
15						
16						
17						
18						
19						
20						
21		8.0				Y
22						
23						
24						
25						
26						
27						
28		8.0				Y
29						
30						
31						

(N = No = Excursion)

Total N's

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 9 1 8 1 0

System Name: Fern Ridge Middle

Sample Period: May 2025
Month/Year

Sample Frequency: Weekly

Distribution Samples required: _____

Number of excursions during this Sample Period = 2

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.8	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Daniel Pustman

Signature: [Signature]

Date: 6.2.25

2