

Lead & Copper Rule Corrosion Control

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1		8.0				Y
2						
3						
4						
5						
6						
7						
8		8.0				Y
9						
10						
11						
12						
13						
14						
15		8.0				Y
16						
17						
18						
19						
20						
21						
22		8.1				Y
23						
24						
25						
26						
27						
28						
29		8.0				Y
30						
31						

(N = No = Excursion)

Total N's

2

<Has sample
met the
minimums?

DISTRIBUTION

PWS ID: 41 9 1 8 1 0

System Name: Fern Ridge Middle

Sample Period: October 2025
Month/Year

Sample Frequency: Weekly

Distribution Samples required: _____

Number of excursions during this
Sample Period = 0

(Number of locations when any WQP
was less than the minimum.)

Note: Entry Point and Distribution
Excursions are cumulative. Add Entry
Point and Distribution Excursions to get
total for sample period.

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.8	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Daniel Putman

Signature: D. Putman

Date: 11. 4. 25