

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	Sample Location	pH	Alk	PO4	Other	Y/N
1						
2						
3						
4						
5		8.3			Y	
6						
7						
8						
9						
10						
11						
12		8.1			Y	
13						
14						
15						
16						
17						
18						
19		8.1			Y	
20						
21						
22						
23						
24						
25						
26		8.4			Y	
27						
28						
29						
30						
31						

(N = No = Excursion)

Total N's

2

<Has sample  
met the  
minimums?

**DISTRIBUTION**

PWS ID: 41 9 1 8 1 0

System Name: Fern Ridge Middle

Sample Period: November 2025  
Month/Year

Sample Frequency: Weekly

Distribution Samples required: \_\_\_\_\_

Number of excursions during this  
Sample Period = 0

(Number of locations when any WQP  
was less than the minimum.)

Note: Entry Point and Distribution  
Excursions are cumulative. Add Entry  
Point and Distribution Excursions to get  
total for sample period.

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	7.8
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	(_____)

Print Name: Daniel Putman

Signature: DR

Date: 12-1-25