



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.96				
2					
3	7.94				
4					
5	8.01				
6					
7					
8	8.11				
9					
10					
11	8.09				
12					
13					
14					
15	7.93				
16					
17	7.89				
18					
19	7.81				
20					
21					
22	7.92				
23					
24					
25	7.96				
26					
27					
28					
29	8.04				
30					
31					

<<Have minimums been met for this day?

County: Lane Agency: LANE COUNTY

ENTRY POINT

EP-A

PWS ID 4191810

FERN RIDGE MIDDLE SCHOOL

Sample period: MARCH 2021
Month/Year


Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.8



Print Name: JEFF HUSSEN

Signature: [Signature]

Date Phone#: 541-935-2253

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0