

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.8				Y
3					
4					
5					
6					
7					
8					
9					
10					
11					
12	7.5				N
13					
14					
15					
16	8.2				Y
17					
18					
19					
20					
21					
22					
23	7.9				Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91810

System Name: FERN RIDGE MIDDLE SCHOOL

Entry Point: WELL

Sample Period: AUG 2021
Month/Year

Number of excursions* during this month: 1
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.8

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: JEFF THIESSEN

Signature: *[Signature]*

Date: 9-3-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 1