

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	8.5				Y
4					
5					
6					
7					
8					
9					
10	8.2				Y
11					
12					
13					
14					
15					
16					
17	8.3				Y
18					
19					
20					
21					
22					
23					
24	8.1				Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Fern Ridge Middle School

Entry Point: Pump House

Sample Period: April 2023  
Month/Year

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months:       
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *( )*

Print Name: Daniel Pruteman

Signature: Dal A [Signature]

Date: 4/24/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's