

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.53				
4	7.48				
5	7.43				
6	7.61				
7					
8					
9					
10	7.85				
11	7.90				
12	7.66				
13	7.68				
14					
15					
16					
17	7.81				
18	7.21				
19	7.54				
20	7.59				
21	FRI				
22	SAT				
23	SUN				
24	7.77				
25	7.70				
26	7.75				
27	7.67				
28	FRI				
29	SAT				
30	SUN				
31	HOLID				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91915

System Name: Merlin

Entry Point: Well House

Sample Period: May 1 - May 31
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

RECEIVED

JUN 11 2021

Data Mgmt & Compliance
Drinking Water Program

Print Name: Ken Benefield

Signature: *Ken Benefield*

Date: 5-3-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's