

Day	pH	Alk	Phos	Other	Y/N
1	8.00				
2	7.88				
3	7.69				
4	FR				
5	SAT				
6	Sun				
7	7.94				
8	7.54				
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	-				
24	7.65				
25					
26					
27					
28					
29	7.82				
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Martin

Entry Point: well house

Sample Period: June 1 - June 30
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input checked="" type="checkbox"/>	
Alk	<input type="checkbox"/>	(Alkalinity)
PO4	<input type="checkbox"/>	(Orthophosphate)
Other	<input type="checkbox"/>	(_____)

RECEIVED
 JUL 23 2021
 Data Mgmt & Compliance
 Drinking Water Program

Print Name: Ken Bennetfield
 Signature:
 Date: 7-5-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's