

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.13				
6					
7					
8					
9					
10					
11					
12					
13	7.09				
14					
15					
16					
17					
18					
19					
20					
21	7.28				
22					
23					
24					
25					
26					
27					
28	7.17				
29					
30					
31					

<<Have minimums been met for this day?



**ENTRY POINT**

PWS ID: 41

System Name: Merlin

Entry Point: Well Room

Sample Period: January / 2022  
 Month/Year


Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH   
 Alk  (Alkalinity)  
 PO4  (Orthophosphate)  
 Other  (\_\_\_\_\_)



Data Mgmt & Compliance  
 Drinking Water Program

Print Name: Keoni Colleges

Signature: [Signature]

Date: 1/28/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's