

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | | | | | |
| 2 | | | | | |
| 3 | | | | | |
| 4 | | | | | |
| 5 | | | | | |
| 6 | | | | | |
| 7 | 7.52 | | | | |
| 8 | | | | | |
| 9 | 7.32 | | | | |
| 10 | | | | | |
| 11 | | | | | |
| 12 | | | | | |
| 13 | | | | | |
| 14 | 7.42 | | | | |
| 15 | | | | | |
| 16 | | | | | |
| 17 | | | | | |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | 7.37 | | | | |
| 22 | | | | | |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | | | | | |
| 30 | 7.43 | | | | |
| 31 | | | | | |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91915

System Name: Merlin (S.O.S.A.)

Entry Point: Well Room

Sample Period: March / 2022
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

RECEIVED
 APR 04 2022
 Data Mgmt & Compliance
 Drinking Water Program

pH 7.3

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Installed secondary pump 3/7/22

Print Name: Keoni Gallegos

Signature: *Keoni Gallegos*

Date: 3/30/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's