

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8	7.40				
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19	7.78				
20					
21					
22					
23					
24					
25					
26					
27					
28	7.63				
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91915

System Name: Merlin (S.O.S.A)

Entry Point: Well Room

Sample Period: April / 2022
Month/Year

Number of excursions* during this month:

(Count the number of days when any WQP was less than the minimum required)



Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Data Mgmt & Compliance Drinking Water Program

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.3	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Keoni Colleges

Signature: [Signature]

Date: 4/28/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's