

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.37				
4					
5					
6					
7					
8					
9					
10					
11					
12	7.42				
13					
14					
15					
16	7.44				
17					
18					
19					
20					
21					
22					
23					
24					
25	7.49				
26					
27					
28					
29					
30	7.48				
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 91915

System Name: Merlin (S.O.S.A)

Entry Point: Well Rooms

Sample Period: August / 2022  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

RECEIVED

SEP 06 2022

Data Mgmt & Compliance  
Drinking Water Program

**Minimum Water Quality Parameters as set by**


pH 7.3

Alk   (Alkalinity)

PO4   (Orthophosphate)

Other   ( )

Print Name: Keoni Gallegos

Signature: 

Date: 8/31/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's