

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.61				
5					
6					
7					
8					
9					
10					
11	7.60				
12					
13					
14					
15					
16					
17					
18					
19	7.58				
20					
21					
22					
23					
24					
25					
26	7.45				
27					
28					
29					
30	7.43				
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Merlin (S.O.S.A)

Entry Point: Well Room

Sample Period: January / 2023
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Keoni Gallegos

Signature: *Keoni Gallegos*

Date: 1/30/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's