

Day	pH	Alk	Phos	Other	Y/N
2					
3	7.71				
4					
5					
6					
7	7.76				
8					
9					
10					
11	7.68				
12					
13					
14					
15					
16					
17					
18	7.59				
19					
20					
21					
22					
23					
24					
25	7.43				
26					
27					
28	7.51				
29					
30					
31	7.48				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 91915

System Name: Merlin (S.O.S.A)

Entry Point: Well Room

Sample Period: August / 2023
Month/Year

Number of excursions* during this month:
 (Count the number of days when any WQP was less than the minimum required)

RECEIVED
 SEP 11 2023
 Data Mgmt & Compliance
 Drinking Water Program

Total excursions during the previous 5 months:
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.3

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Keoni Gallegos

Signature: *Keoni Gallegos*

Date: 8/31/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's