

Day	pH	Alk	Phos	Other	Y/N
1	7.5	140	56.8	2.6	Y
2	7.6	160	56.7	2.6	Y
3					
4					
5					
6					
7	7.7	200	59.0	2.0	Y
8	7.7	180	59.4	1.6	Y
9	8.0	160	60.4	1.8	Y
10					
11					
12					
13	8.1	140	59.2	1.0	X
14	7.9	160	58.6	1.2	Y
15	7.7	140	58.6	0.8	Y
16	8.0	140	56.3	0.8	Y
17					
18					
19					
20	8.3	140	57.6	0.8	Y
21	8.1	140	57.2	0.8	Y
22	8.3	160	57.7	0.8	Y
23					
24					
25					
26					
27	8.4	180	57.0	1.2	Y
28	8.5	180	55.9	1.2	Y
29	8.5	200	55.4	1.2	Y
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: LINCOLN COUNTY

**ENTRY POINT
EP-B**

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample period: September 2021
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Jason Brooks
 Signature: [Signature]
 Date & Phone#: 541-875-2942

Send to DWP within 10 days after end of sampling period

Y = N = Excursion) Total N's 0