

Temp Chlor

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	8.4	200	53.8	1.2	Y
7					
8					
9					
10					
11	8.4	200	51.8	1.2	Y
12					
13	8.4	200	51.1	1.4	Y
14	8.3	200	52.3	1.2	Y
15					
16					
17					
18	8.0	180	52.0	1.0	Y
19					
20	7.9	180	53.1	0.8	Y
21					
22					
23					
24					
25	7.7	180	52.9	0.8	Y
26	8.3	200	52.3	0.8	Y
27	8.1	180	53.8	1.0	Y
28					
29					
30					
31	7.6	180	52.3	1.0	Y

<<Have minimums been met for this day?

County: Lincoln Agency: LINCOLN COUNTY

ENTRY POINT

EP-B

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample period: October 2021
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Jason Brooks

Signature: [Signature]

Date & Phone#: 541-875-2942 11-4-21

Send to DWP within 10 days after end of sampling period

Y = N = Excursion) Total N's 0