

Temp Chlor

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.7	180	52.4	1.0	Y
3					
4					
5					
6					
7					
8	7.8	180	49.3	1.0	Y
9					
10					
11					
12					
13					
14					
15	7.7	200	53.6	1.0	Y
16	7.8	180	52.0	1.0	Y
17					
18					
19					
20					
21					
22					
23	7.5	180	46.2	0.8	Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Lincoln Agency: LINCOLN COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4192040**

**EDDYVILLE CHARTER SCHOOL**

Sample period: November 2021  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: Jason Brooks

Signature: [Signature]

Date & Phone#: 541-875-2942 11-8-21

Send to DWP within 10 days after end of sampling period

(= N = Excursion) Total N's 0