

Day	pH	Temp	Chlor	Other	Y/N
1					
- 2	7.9	55	1	-	y
3					
- 4	7.9	54	.9	-	y
5					
6					
7					
8					
- 9	8	54	1	-	y
10					
- 11	8	54	.9	-	y
12					
13					
14					
15					
- 16	7.9	55	1	-	y
17					
- 18	7.9	55	1	-	y
19					
20					
21					
22					
- 23	7.5	55	1.1	-	y
24					
- 25	7.9	55	1.2	-	y
26					
27					
28					
29					
- 30	8	54	1	-	y
31					

<<Have minimums been met for this day?

County: Lincoln Agency: LINCOLN COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4192040**

**EDDYVILLE CHARTER SCHOOL**

Sample period: \_\_\_\_\_

*Dec 01*  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2

Print Name: *Danna Wheeler*

Signature: \_\_\_\_\_

Date & Phone# *12/1/01*

Send to DWP within 10 days after end of sampling period

( ) = N = Excursion) Total N's 0