

Lead & Copper Rule Corrosion Control

	Day	pH	Temp	Chlor	Other	Y/N
S/	1	7.8	SS	1	✓	Y
	2					
	3					
	4					
S/	5	7.9	SS	1	✓	Y
	6					
S/	7	8	SS	1.2	—	Y
	8					
	9					
	10					
	11					
	12					
S/	13	8	SS	1.2	✓	Y
	14					
S/	15	8	SS	1.1	—	Y
	16					
	17					
	18					
	19					
S/	20	7.9	SS	1	✓	Y
	21					
S/	22	7.9	SS	1	✓	Y
	23					
	24					
	25					
S/	26	7.9	SS	1.2	✓	Y
	27					
S/	28	8	SS	1	✓	Y
	29					
	30					
	31					

<<Have
minimums
been met for
this day?

County: Lincoln Agency: LINCOLN COUNTY

ENTRY POINT

EP-B

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample period: May / 2025
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: [Signature]
Signature: [Signature]
Date & Phone#: 5/6/25

Send to DWP within 10 days after end of
sampling period

= N = Excursion) **Total N's** 0