

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Temp	Chlor	Other	Y/N
1	7.9	56	1	/	
6/2					Y
3					
6/4	7.8	55	1	/	Y
5					
6					
7					
8					
9					
6/10	8	55	1	/	Y
11					
6/12	8	56	1.1	/	Y
13					
14					
15					
6/16	7.9	56	1.1	/	Y
17					
6/18	7.9	56	1	/	Y
19					
20					
21					
22					
23					
6/24	7.9	56	1	/	Y
25					
6/26	8	56	1	/	Y
27					
28					
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Lincoln Agency: LINCOLN COUNTY

**ENTRY POINT**

**EP-B**

**PWS ID 4192040**

**EDDYVILLE CHARTER SCHOOL**

Sample period: Jun / 28  
Month/Year

Number of excursions during this month: 6

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
cumulative). An 'excursion' is any day in which the  
water quality parameter(s) fall below the minimum  
set by the State.

**Reference**

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2

Print Name: Danny White

Signature: [Signature]

Date & Phone#: 7/6/25

Send to DWP within 10 days after end of  
sampling period

( ) = N = Excursion) **Total N's** 6