

Lead & Copper Rule Corrosion Control

Day	pH	Temp	Chlor	Other	Y/N
1					
2/2	8.1	57	3.4	/	Y
3					
2/4	8	56	3.4	/	Y
5					
6					
7					
8					
2/9	8.3	56	3.4	/	Y
10					
2/11	8.2	57	3.4	/	Y
12					
13					
14					
15					
2/16	8.2	57	3.4	/	Y
17					
2/18	8.2	58	3.4	/	Y
19					
20					
21					
22					
2/23	8.3	58	3.4	/	Y
24					
25					
2/26	8.3	59	3.4	/	Y
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Lincoln

Agency: LINCOLN COUNTY

ENTRY POINT

EP-B

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample period: Feb / 26

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Danny Wheeler

Signature: [Signature]

Date & Phone#: 2 / 26 / 26

Send to DWP within 10 days after end of sampling period

= N = Excursion) **Total N's** 0