

Lead & Copper Rule Corrosion Control

Temp Chlor

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
10/6	<i>Rm. 26</i>	8.3	/	58.3	1.6	Y
10/11	↓	8.2	/	58.8	1.8	Y
10/13		8.1	/	58.8	1.6	Y
10/14		8.0	/	60.6	1.6	Y
10/18		7.9	/	57.0	0.6	Y
10/20		8.0	/	60.6	0.6	Y
10/25		8.0	/	59.9	0.8	Y
10/26		7.8	/	59.4	0.8	Y
10/27		8.1	/	56.8	1.6	Y
10/31		7.7	/	58.1	1.6	Y

<Has sample met the minimum(s)?

County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040

EDDYVILLE CHARTER SCHOOL

Sample Period: October 2021
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

(N = No = Excursion) Total N's 0

Print Name: Jason Brodes
Signature: [Signature]
Date: 11-4-2021