

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
11/2	Rm. 26	7.7		58.3	1.4	Y
11/8	↓	7.7		57.4	0.8	Y
11/15		7.6		59.5	0.4	Y
11/16		7.7		58.3	1.0	Y
11/23		7.4		54.0	1.0	Y

TEMP Chlor

<Has sample met the minimum(s)? **DISTRIBUTION**
 County: Lincoln Agency: LINCOLN C

PWS ID 4192040
EDDYVILLE CHARTER SCHOOL

Sample Period: November 2021
 Month/Year
 Sample Frequency: Every 6 months
 Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Jason Brooks
 Signature: [Signature]
 Date: 12-8-2021

(N = No = Excursion) Total N's