

Lead & Copper Rule Corrosion Control

Temp Chlor

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
12/1	Rm. 26	8.2	60.4	1.0	/	Y
12/6		8.1	57.2	1.2	/	Y
12/13		8.3	52.5	1.2	/	Y
12/20		8.2	48.1	1.2	/	Y
12/29		8.1	48.1	1.2	/	Y

(N = No = Excursion) Total N's

<Has sample met the minimum(s)? County: Lincoln Agency: LINCOLN C

DISTRIBUTION

PWS ID 4192040
EDDYVILLE CHARTER SCHOOL

Sample Period: December 2024
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 1

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Jason Brooks
Signature: [Handwritten]
Date: 1-5-2022